



Product Service


# CERTIFICATE

No. Z2 001309 0007 Rev. 00

**Holder of Certificate:** **Yixing JS Solar Co., Ltd.**

No. 501, LvYuan Road  
Environment Science&Technology Mansion  
Environment Protection and  
Science&Technology Industry Park  
214200 Yixing  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:**

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704062017903-00

**Valid until:** 2025-06-21

**Date,** 2020-07-09

( Zhulin Zhang )



# CERTIFICATE

No. Z2 001309 0007 Rev. 00

**Model(s):** JSxxxM144, xxx=365 to 405 in step of 5,  
 JSxxxM120, xxx=305 to 340 in step of 5,  
 JSxxxP144, xxx=320 to 360 in step of 5,  
 JSxxxP120, xxx=265 to 300 in step of 5,  
 xxx is standing for rated output power at STC

**Parameters:**

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500V DC
Fire Safety Class:	Class C according to UL790

**Tested according to:** IEC 61215-1:2016  
 IEC 61215-1-1:2016  
 IEC 61215-2:2016  
 IEC 61730-1:2016  
 IEC 61730-2:2016  
 IEC 62716:2013

**Production Facility(ies):** 004170