



Product Service


CERTIFICATE

No. Z2 001309 0008 Rev. 00

Holder of Certificate: **Yixing JS Solar Co., Ltd.**

No. 501, LvYuan Road
Environment Science&Technology Mansion
Environment Protection and
Science&Technology Industry Park
214200 Yixing
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Poly-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062017901-00

Valid until: 2025-06-21

Date, 2020-07-09

(Zhulin Zhang)



CERTIFICATE

No. Z2 001309 0008 Rev. 00

Model(s): JSxxxP144, xxx=320 to 360 in step of 5,
 JSxxxP120, xxx=265 to 300 in step of 5,
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL 790
PID test condition:	-1500 V DC, 85 °C, 85 % RH, 96h
PID testing method is according to IEC TS 62804-1:2015.	

Tested according to: IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 PPP 58042B:2015

Production Facility(ies): 004170